

**ADDENDUM-II****Tender No. 1070C18043 for Supply of Flameproof LED Lighting fixtures at ONGC Mangalore Petrochemicals Ltd (OMPL) - An SEZ Unit**

Addendum-II to tender document is as follows:

Sl.	Query	OMPL Replies/Clarifications/Amendment/Corrigendum
1	Please confirm the requirement of area classification Zone-1/2 for Ex'nR' light fitting, since Indian certification agency allow Ex'nR' Light fitting for Zone 2 application only	Item no. 4, 5, 8 & 9 of the SOR, Zone-1/2 shall be read as Zone-2. Same is applicable for the specifications mentioned in tender documents for the above line items
2	LAST DATE FOR SUBMISSION OF BID: 15:00 HOURS (IST) ON 02-Jan-2019	The last date of Bid submission due date for the above referred tender stands extended upto 15:00 Hrs (IST) on 08-Jan-2019. Unpriced Techno-Commercial bid shall be opened at 15:30 hours (IST) on extended date of bid submission.

All other terms & conditions, stipulations, specifications etc. of tender document issued earlier shall remain unaltered. This forms an integral part of bidding document. Bidders are requested to take cognizance of the same and submit their bids accordingly. Bidders are requested to submit the copy of this document duly signed & stamped along with the bid (in the techno-commercial part) as the token of acknowledgement & acceptance of the same.

Sign & Stamp of Bidder