



ADDENDUM-I
Tender No. 1070C19049 for Supply of Weatherproof LED Lighting Fixture at ONGC Mangalore Petrochemicals Ltd (OMPL) - An SEZ Unit



Addendum-I to tender document is as follows:

Sl.	Query	OMPL Replies/Clarifications/Amendment/Corrigendum
1	As per the pre-qualification criteria ii) past experience, one completed work of > 53.88 Lakhs, since we are NSIS (small scale Industry) and we have one completed work of Rs.44 Lakhs of ICICI Prudential, we would like to know whether we can able participate in the tender	15% relaxations in line with Ministry Guideline is applicable. Tender conditions shall prevail.
2	As per other technical specification and scope tender document, make of Light fittings makes are only standard and reputed make. With reference to the same, we wish to inform you that the standard make are binding the criteria of bidding. In view of the same, you are requested to kindly add our make UNISTAR or add equivalent in the tender as we are already doing the LED Lighting work in various department of government, PSU & etc.	Makes mentioned under Suggested makes are only for reference purposes, any fixtures matching the technical specifications & OEM qualifying the PQC & BEC is allowed.
3	With above reference for the tender make in some column mentioned name or equivalent, can we participate in this tender. We request you please give opportunity , to Surya make to quote	Makes mentioned under Suggested makes are only for reference purposes, any fixtures matching the technical specifications & OEM qualifying the PQC & BEC is allowed.
4	Lumens required for High Bay Light as per tender. 3. Suitable Replacement fixture for 400W HPMV / 250W HPSV High Bay Fixture • Power – Maximum 100W including driver losses • System level lumen output – minimum 14000 lumens 4. Suitable Replacement fixture for 150W HPSV Medium Bay Fixture • Power – Maximum 80W including driver losses • System level lumen output – minimum 12000 lumens Request you to consider 12000 lm for 100 W and 9600 lm for 80 W.	Tender specifications shall prevail.

5	PO copies are being placed on the authorized channel partner of OEM. So can we give the reference of those PO copies as in different areas channel partner is different	Same shall be considered with submission of proper documents for traceability
6	For Sr. No. 3,4,5 & 6 of the product, CCT is mentioned as 5000K. Requested to provide a range for the same instead of single value	CCT revised for products under Sr. No. 3,4,5 & 6 to 5000K - 6500K
7	Item no 3- 100W High/Medium bay requires system lumens @ 140lm/w at CCT -5000K. Moment you go towards warmer colour LED's, lumen o/p decreases. CCT should be 5700-6500K	CCT can be considered 5000 - 6500K
8	Item no 4- Similarly for 80W high/medium bay requires system lumens @ 150 lm/w at CCT -5000K	CCT can be considered 5000 - 6500K
9	Item no 5 & 6- Well glass 40W & 70W requires system lumens >100lm/w at CCT -5000K .It should be 90-100lm/w for this CCT. Also IP protection in well glass asked for IP66. Well glass is generally IP65 whether it indoor or outdoor and preferably used indoors.	CCT can be considered 5000 - 6500K IP66 protection only will be acceptable
10	Item no 10 -20W LED 4 feet batten, IP65 CRCA/Aluminum. IP65 batten comes in PC/PC version and not in CRCA/aluminium	PC/PC version will be acceptable.
11	LAST DATE FOR SUBMISSION OF BID: 15:00 HOURS (IST) ON 12-Dec-2019	The last date of Bid submission due date for the above referred tender stands extended upto 15:00 Hrs (IST) on 24-Dec-2019. Unpriced Techno-Commercial bid shall be opened at 15:30 hours (IST) on extended date of bid submission.

All other terms & conditions, stipulations, specifications etc. of tender document issued earlier shall remain unaltered. This forms an integral part of bidding document. Bidders are requested to take cognizance of the same and submit their bids accordingly. Bidders are requested to submit the copy of this document duly signed & stamped along with the bid (in the techno-commercial part) as the token of acknowledgement & acceptance of the same.

Sign & Stamp of Bidder